

TOWN OF WALLACE POTABLE WATER SPECIFICATIONS

All meters installed by contractor will be Hersey Hot Rod Radio Read (no exceptions)

All meters over 1 inch will be compound

Meter sizes required $\frac{3}{4}$, 1, 2, 4, 6, 8, no 1 $\frac{1}{2}$ or 3 inch meters allowed

Contractors will do all taps and will provide valves with brass fittings on both sides of road if bore required

All meters 1 inch and above will require RPZ backflow device above ground

Per State Law, some $\frac{3}{4}$ " services may require backflow protection

$\frac{3}{4}$, 1 and 2 inch require setters

Backflow devices will be on pad and in a hot box to prevent freezing

Meter boxes will be PVC type of the appropriate size

Contractors will call town forces to observe tap

No taps will be done weekdays after 4:00pm, on weekends or holidays (town observed)

All bores will be encased with steel or ductile iron pipe

Lines will be encased if run across ditches with steel or ductile iron pipe

Gasket joints on DOT ROW's

Lines will be pressure tested and town forces must observe

DENR requirements for disinfection and town to have BacT results before service

Engineer certification required BEFORE SERVICE ACTIVATED

Engineer responsible for inspections

C900 pipe shall be used