

Town of Wallace Pump Station Specifications:

NOTE: THESE ARE ABOVE STATE MINIMUM STANDARDS

Pumps shall be submersible of the ABS type

Contractor shall supply town with 1 (one) extra pump

Contractor shall supply town with as-builts of station and F/M drawings

Electrical rack will face pump station

Phone lines will be hooked up to dialer and ready for town to assume

Pumps will be on rail system and stainless steel cable will be attached

Contractor will provide stainless steel wench and bracket (wench to be removable)

All equipment will be under stainless steel Rain shield (see attached illustrations)

4 foot concrete pad walkway in front of electrical panel

Generator or Pump shall be provided

All valves will be in separate vault w\drainage to station

Back-up pump hook-up 4" with valve(vaulted)

Yard hydrant with RPZ

All lift stations shall be enclosed in 6 foot chain link fence with 8 foot gate

No galvanized pipe, DI (Ductile Iron) must be used

Schedule 80 for 2 inch

ALL GRAVITY SEWERMAINS WILL BE C900 NO EXCEPTIONS!

Contractor upgrades of stations are required to adhere to these specs.